



	PA0491 1931-3-1	PA0809 1931-3-2	PA0873 1931-3-3	PA0874 1931-3-4
R10	0E18 5W	0E18 5W	0E18 5W	0E18 5W
R28	NF	0E18 5W	NF	0E18 5W
R52	100E 5W	100E 5W	NF	NF
R53	100E 5W	100E 5W	NF	NF
R42	6A PTC	NF	6A PTC	1N

UNLESS OTHERWISE STATED:
 ALL RESISTORS 1/4W, 5%
 ALL RESISTANCE IN OHMS
 ALL CAPACITANCE IN FARADS

PA0491	1931-3-1	F3200 MAF / PSU 3A
PA0809	1931-3-2	F3200 MAF / PSU 6A
PA0873	1931-3-3	F3200 4428.1 MAF / PSU 3A
PA0874	1931-3-4	F3200 4428.1 MAF / PSU 6A

CONFIDENTIAL: THIS DOCUMENT MUST NOT BE COPIED NOR THE CONTENTS PASSED ON TO ANY THIRD PARTY WITHOUT THE CONSENT OF THE COMPANY.

ISS/REV	AMENDMENTS	ECO	DRN	CHKD	AUTH	APVD	DATE
8	C21 WAS 2N2	3034	GEL	KJS	TWH	DSCP	8.11.99
8.1	PA0873, PA0874 ADDED. TABLE FOR R28, R52, R53 VALUES ADDED	3041	TWH	LM	TWH	DSCP	4.4.00
9	C21 & C28 ADDED	3158	CEA	DS	RAC	DSCP	19.4.01
10	D10 WAS TYPE MTP2955	3834	GEL	PAA	LSC	DSCP	21.03.07

tyco Safety Products
 17 MARY MULLER DRIVE,
 P.O. BOX 19-545,
 CHRISTCHURCH TEL: +64 3 389-5096
 NEW ZEALAND FAX: +64 3 389-5938

F3200 / F3200 4428.1 MAF / PSU CIRCUIT DIAGRAM

DRAWING No: **1931-3** SHEET **1** of **1**

A1	ISS/REV 10	PART No: SEE ABOVE
-----------	-------------------	---------------------------

2-Apr-2007
09:33:20