



CONFIDENTIAL: THIS DOCUMENT MUST NOT BE COPIED NOR THE CONTENTS PASSED ON TO ANY THIRD PARTY WITHOUT THE CONSENT OF THE COMPANY.

UNLESS OTHERWISE STATED: ALL DIMENSIONS IN MILLIMETRES. DO NOT SCALE. TOLERANCES ARE TO BE: 1 DECIMAL PLACE ±0.5, 2 DECIMAL PLACES ±0.3, 3 DECIMAL PLACES ±0.1

3rd ANGLE PROJECTION

ISS/REV	AMENDMENTS	ECO	DRN	CHKD	AUTH	APVD	DATE
A	ORIGINAL	3325	RMH				7-11-02
B	BLACK 0.5sqmm REMIT WIRE ADDED FROM 0V TO 8 RELAY MODULE BOARD	3325	RMH	GEL	DJG	DSCP	16-12-02
C	GAS DISCHARGED LED WAS RED, DETAIL B ADDED.	3572	KJS	PA	SC	DS	13-9-04

tyco / Safety Products

TYCO SAFETY PRODUCTS
 211 MACES RD PH: +64 3 3895096
 P.O. BOX 19545 FAX: +64 3 3895938
 CHRISTCHURCH, NEW ZEALAND

F3200 AS4428
7U 1 ZONE GAS FLOOD DOOR
LOOM / WIRING DIAGRAM

DRAWING No: **1931-123** SHEET **1** of **1**

A3	ISS/REV C	PART No: ME0438
-----------	------------------	------------------------