

Simplex TrueSTART Instrument II

Information for Australian Users

This TrueSTART Instrument has been adjusted for use with 4100 systems in Australia.

Some of the sections in the User Manual (579-1030) do not apply or need to be qualified, as listed in the following section.

Affected sections of User Manual

- AC Adapter (page 4) – the TSI II is supplied in Australia with a 24V mains plug pack which meets the local RCM requirements.
- IDNAC and IDNAC Tests (pages 10 and 11) – IDNAC devices are not used in Australia. You can ignore these sections.
- Battery Charger (page 17) - the TSI II is supplied in Australia with a 24V mains Li-Ion battery charger which meets the local RCM requirements.
- IDNAC Device Types, Error Messages, Configuration Information (pages 20 and 21) – these devices are not used in Australia, so these sections can be ignored.
- Replacement Parts (page 23) – the order codes in this part are not valid in Australia. Refer to the following

section for ordering codes for spares.

Spare Part Ordering Codes

Spare parts can be ordered from Simplex Customer Service at 1300 725 688 in Australia using these part codes:

- TSIT-AUK - TrueStart Instrument II kit includes test leads, charger, AC power adaptor, serial leads, USB – serial converter and carry bag.
- TSIT-ALEADS - Australian replacement lead set contains replacement test leads and DC supply harness for TSIT-AUK.

TFPP does not directly stock the 24V 1A mains plug pack. A suitable spare part is Altronics M9391A.

Technical Support

For Technical Support for this or any other Tyco Fire Protection product, please contact us on 1300 552 559.

